

# PRODUCT DATA SHEET

## Lightning protection systems

### Fasteners for lightning protection conductors

**Code: 6121200-71**

**Description: Copper fastener for tape conductor up to 30mm width, code 6121200-71**

#### Application

Fastening tape conductor. Used in air termination system, down conductor system. Suitable for brick or concrete surfaces.

#### Classification as per IEC EN 62561

- Metallic.
- With screws.
- Designed to clamp but allow axial movement of the conductor.



#### Technical characteristics - Installation instructions

Material	Copper (Cu)
Screws	M6x16 mm, V2A stainless steel screws, one stainless steel wood fixing screw
Withstands (according to IEC EN 62561-4)	Lateral load, 200 N / Axial load, 50 N
Conductor's dimensions	Up to 30x6 mm
Compatibility with conductors made of	Cu, Cu/eSn, SSt (Stainless Steel)
Tightening torque of conductor	3,5Nm
Fixing on brick or concrete	Through a wood fixing screw (included) and a PVC wall plug Ø8 mm (not included)
Spacing between fasteners of air termination conductors	≤500 mm1).
Spacing between fasteners of down conductors	≤1000 mm for heights ≤20 m. / ≤500 mm for heights ≥20 m.
Before and after of change of direction or clamp or contraction-expansion absorbing component.	≤300 mm.

## Testing as per IEC EN 62561

The component has successfully passed the testing requirements of standard IEC EN 62561-4 "Lightning protection system components (LPSC) – Part 4 : Requirements for conductor fasteners".

Test report No **31390** by accredited laboratory as per ISO 17025

## ELEMKO management systems

- ISO 9001
- ISO 14001
- ISO 45001

## Country of Origin

Greece

## Optional accessories

PVC sealing washer, ELEMKO code 61 03 201

## Unit: piece / Package: 50 pieces

1) Where additional mechanical strength is required, e.g snow, strong winds etc, the spacing between the fasteners should be  $\leq 300$  mm.

We reserve the right to introduce changes in the component due to technical evolution.