

# PRODUCT DATA SHEET

## Earthing components

### Connection components for earth conductors

### Substation earthing

**Code: 6224040-71**


**Description: Copper tape (40mm/40mm) clamp, code 6224040-71**

#### Application

Clamp, for connecting tape conductors. Used in air termination system, down conductor system, earthing system.

#### Classification

- Heavy duty (H – 100 kA) (1)
- General use (1)
- Intended to withstand a static mechanical load (1)
- Non-permanent connection (1)
- Short circuit withstand capability 25 kA rms for 1s  
(1) As per IEC EN 62561



#### Technical characteristics - Installation instructions

Material	Copper (Cu)
Description	Is consisted of two plates with dimensions 70x70 mm.
Bolts / nuts	M8x30 mm, V2A stainless steel hexagon head bolts. / M8 V2A stainless steel nuts.
Tape's dimensions	Up to 40 mm width and 6 mm thickness.
Connection arrangements	Cross connection (B1). / Parallel connection (B2).
Installation	Above ground, buried in ground, embedded in concrete.
Can be connected above ground with	Cu, Cu/eSn, Stainless Steel (SSt).
Can be connected buried in ground with	Cu, Cu/eSn, Stainless Steel (SSt).
Can be connected in concrete with	Cu, Cu/eSn, Stainless Steel (SSt), St/tZn.

Tightening torque	13 Nm.
-------------------	--------

## Testing

The component has successfully passed the testing requirements of standard IEC EN 62561-1 "Lightning protection system components (LPSC) – Part 1 : Requirements for connection components". Test report No **30120** by accredited laboratory as per ISO 17025.

The component has successfully passed short circuit withstand capability tests. Test report No **1405/2022/DKK-14**

## ELEMKO management systems

- ISO 9001
- ISO 14001
- ISO 45001

## Country of Origin

Greece

## Unit: piece / Package: 15 pieces

We reserve the right to introduce changes in the component due to technical evolution.