PRODUCT DATA SHEET

Earthing components

Connection components for earth conductors

Substation earthing

Lightning protection systems

Connection components for LPS conductors

Code: 6261833-71
Description: Stainless steel tape (30mm/30mm) clamp, code 6261833-71

Application

Clamp, for connecting tape conductors. Used in air termination system, down conductor system, earthing system.



Classification

- Heavy duty (H – 100 kA) (1)
- General use (1)
- Intended to withstand a static mechanical load (1)
- Non-permanent connection (1)
- Short circuit withstand capability 20 kA rms for 1s

(1) As per IEC EN 62561

Technical characteristics - Installation instructions

Material	Stainless steel (SSt grade V2A).
Description	Is consisted of two external plates with dimensions 50x50 mm and one intermediate plate.
Bolts / nuts	M6x25 mm, V2A stainless steel carriage bolts. / M6 V2A stainless steel nuts.
Tape's dimensions	Up to 30 mm width and 5 mm thickness.
Connection arrangements	Cross connection (B1). / Parallel connection (B2).
Installation	Above ground, buried in ground, embedded in concrete.
Can be connected above ground with	Al, Cu, Cu/eSn, Stainless Steel (SSt), St/tZn.
Can be connected buried in ground with	Cu, Cu/eSn, Stainless Steel, St/tZn (St/tZn not simultaneously with Cu).

Can be connected in concrete with	Cu, Cu/eSn, Stainless Steel (SSt), St/tZn.
Tightening torque	9 Nm.

Testing

The component has successfully passed the testing requirements of standard IEC EN 62561-1 “Lightning protection system components (LPSC) – Part 1 : Requirements for connection components”. Test reports No **30750 & 30835** by accredited laboratory as per ISO 17025.
The component has successfully passed short circuit withstand capability tests. Test report No **1405/2022/DKK-12**

ELEMKO management systems

- ISO 9001
- ISO 14001
- ISO 45001

Country of Origin

Greece

Unit: piece / Package: 25 pieces

We reserve the right to introduce changes in the component due to technical evolution.