PRODUCT DATA SHEET

Earthing components

Lightning protection earthing

Lightning protection systems

Lightning Protection System (LPS) conductors

Code: 6420195-70

Description: 95mm2 nominal cross sectional area copper stranded conductor, code 6420195-70

Application

Copper stranded conductor used as air termination conductor, down conductor and earth conductor.

Technical characteristics - Installation instructions

Diameter	12,60 mm.
Cross sectional area	95 mm2.
Material	Copper (Cu).
Electrical resistivity	<0,018 μΩm.
Electrical resistance	≤0,195 Ω/km.
Tensile strength	200 – 450 N/mm2.
Installation	Above ground, buried in ground, embedded in concrete.
Can be connected above ground with	Cu, Cu-A (copper alloy), Cu/eSn, Stainless Steel (SSt), St/eCu.
Can be connected buried in ground with	Cu, Cu-A (copper alloy), Cu/eSn, Stainless Steel (SSt), St/eCu.
Can be connected in concrete with	Cu, Cu-A (copper alloy), Cu/eSn, Stainless Steel (SSt), St/eCu, St/tZn.

Testing as per IEC EN 62561

The component has successfully passed the testing requirements of standard IEC EN 62561-

2 “Lightning protection system components (LPSC) – Part 2 : Requirements for conductors and earth electrodes”.
Test report No **31091** by accredited laboratory as per ISO 17025.

ELEMKO management systems

- ISO 9001
- ISO 14001
- ISO 45001

Country of Origin

Greece

Needed accessories

Clamps (e.g. 6222112), fasteners (e.g. 6121112) for the spacing consult fasteners' installation instructions.

Unit: meter / Package: 70 m approx. / 0,833 kg/m

We reserve the right to introduce changes in the component due to technical evolution.