

PRODUCT DATA SHEET

Earthing components Substation earthing

Code: 6224417-71


Description: Copper connector for substation grounding (IEEE 837), for rod to tape connection, code 6224417-71

Application

Clamp, for connecting round rod to tape conductor. Used in substation grounding.

Classification as per IEEE 837

- Electromagnetic force withstand:
Asymmetrical current 106 kA first peak, 45 kArms @ 150ms
- Fault current withstand: 7,8 kA @ 10s
- Corrosion withstand: 500h of continuous salt spray



Technical characteristics - Installation instructions

Material	Copper (Cu)
Description	It is consisted of two plates with dimensions 70x70 mm.
Bolts / nuts	M8x30 mm, V2A stainless steel hexagon head bolts. M8 V2A stainless steel nuts, washers & spring lock washers.
Rod's dimensions	Ø17 mm.
Tape's dimensions	20 – 40 mm & up to 5 mm thickness.
Connection arrangements	Cross. / Parallel.
Installation	Above ground, buried in ground, embedded in concrete.
Can be connected above ground with	Cu, Cu/eSn, Stainless Steel (SSt), St/eCu.
Can be connected buried in ground with	Cu, Cu/eSn, Stainless Steel (SSt), St/eCu.
Can be connected in concrete with	Cu, Cu/eSn, Stainless Steel (SSt), St/eCu, St/tZn.

Tightening torque 20 Nm.

Testing as per IEEE 837

The component has successfully passed the testing requirements of standard IEEE std 837: "IEEE standard for qualifying permanent connections used in substation grounding".
Test report No **32165** by accredited laboratory as per ISO 17025

ELEMKO management systems

- ISO 9001
- ISO 14001
- ISO 45001

Country of Origin

Greece

Unit: piece / Package: 20 pieces

We reserve the right to introduce changes in the component due to technical evolution.