

PRODUCT DATA SHEET

LIGHTNING PROTECTION AND EARTHING SYSTEM COMPONENTS

Code: 62 45 040

Description: Al – St/tZn test clamp


ed.02/2021

Application

Test clamp for solid round or stranded conductors. Used in down conductor system. It can be installed 1,5–2 m above ground level at each down conductor. It is used to facilitate the electrical testing and measurements of Lightning Protection System.

Classification as per IEC EN 62561

- Normal duty (H – 50 kA)
- General use
- Not intended to withstand a static mechanical load
- Non-permanent connection



Technical characteristics

Material	Aluminium (body – base of screw terminal) Hot dip galvanized steel (screw terminal)
Description	Is consisted of two parts interconnected with two stainless steel screws and nuts. The tightening of the conductor to each part is achieved with a special design screw terminal M10x25 mm and a M10 nut.
Bolts / nuts	M8x20 mm, V2A stainless steel hexagon head bolts, M8 V2A stainless steel nut, M10 hot dip galvanized steel nut.

Installation instructions

Conductor's dimensions	Ø10 mm
Connection arrangement	In–line (B3)
Installation	Above ground
Can be connected with	Al, SSt (Stainless Steel), St/tZn
Tightening torque	13 Nm (M8), 17 Nm (M10)

Testing as per IEC EN 62561

The component has successfully passed the testing requirements of standard IEC EN 62561-1 “Lightning protection system components (LPSC) – Part 1 : Requirements for connection components”.
Test report No **31280** by accredited laboratory as per ISO 17025


Manufacturing Quality Control

Manufacturing quality control according standard ISO 9001

Country of Origin

Greece

Unit: piece / Package: 25 pieces



We reserve the right to introduce changes in the component due to technical evolution.