



Detail A
 (1) : Ms/eNi Franklin mast $\varnothing 30 \times 2000$ mm
 ELEMKO code 64 21 103 tested according
 IEC EN 625641 - 2 and (2) SSt/V2A tube
 $\varnothing 35 \times 3000$ mm ELEMKO code 60 60 33

Detail B
 (3) Cu/eNi Franklin connector ELEMKO code
 65 21 031 tested according IEC EN 62561 - 1
 and (4) copper $\varnothing 8$ mm round conductor ELEMKO
 code 64 20 008 tested according IEC EN 62561 - 2

Detail C
 (5) SSt adjustable pipe clamp ELEMKO code 65 62 203
 for pipe 3/4" - 2" tested according IEC EN 62561 - 1 and
 (4) copper $\varnothing 8$ mm round conductor ELEMKO code
 64 20 008 tested according IEC EN 62561 - 2

Detail D
 (4) copper $\varnothing 8$ mm round conductor ELEMKO code
 64 20 008 tested according IEC EN 62561 - 2

		Title:	
		DRG NO. 094-0	
FIRST ISSUED	February 2020	 www.elemko.gr 	
DRAWN BY	Dionysopoulos G.		
CHECKED BY	Valirakis G.	 www.elemko.gr 	
APPROVED BY	Kokkinos D.		
SCALE	None	SHEET 1 OF 1	
ISSUANCE DATE	February 2020		