




(13):Cu/eSn equipotential earthing bar ELEMKO code 66 20 004 tested according IEC EN 62561 - 1, (8) press terminal for cable 25 mm² ELEMKO code 65 22 025 and (7) Cable H07V-R 25mm² ELEMKO code 64 26 225 & (5) Solid round conductor St/tZn, 10mm diameter, ELEMKO code 64 00 011 tested according IEC EN 62561 - 2 (15) low voltage limiter (isolating spark gap) ELEMKO code 66 01 101 and (14) press terminal for Ø10 round conductor ELEMKO code 65 22 070

		Title:	
		Voltage limiter installation for DC corrosion current decoupling	
FIRST ISSUED	July 2019	DRG No.	086-6
DRAWN BY	Dionysopoulos G.		
CHECKED BY	Kokkinos N.	 www.elemko.gr 	
APPROVED BY	Kokkinos N.		
SCALE	None	SHEET 5 OF 5	
ISSUANCE DATE	July 2019		