



(1): Aluminium \varnothing 8-10 test clamp ELEMKO code 62 45 000 tested according IEC EN 62561 - 1 with (2) Aluminium round conductor ELEMKO code 64 40 008 tested according IEC EN 62561 - 2 and (3) St/tZn \varnothing 10 round conductor ELEMKO code 64 00 011 tested according IEC EN 62561 - 2

(4): St/tZn fastener ELEMKO code 61 01 100, for round conductor 8-10mm. 1 fastener per 1m of solid round conductor, tested according IEC EN 62561 - 4

(5): St/tZn L=1500 earth rod cross profile ELEMKO code 63 00 015 with (11) St/tZn double bonding clamp ELEMKO code 62 05 201 tested according IEC EN 62561 - 1

(7): Anticorrosion tape ELEMKO code 61 03 303 and (3) St/tZn round conductor ELEMKO code 64 00 011 tested according IEC EN 62561 - 2

(8): St/tZn end clamp ELEMKO code 65 04 402 tested according IEC EN 62561 - 1 with (9) Al - St/tZn single bonding clamp ELEMKO code 62 45 141 tested according IEC EN 62561 - 1, (4.1) Aluminium blind rivet nut ELEMKO code 65 04 403 and (4.2) hexagon screw ELEMKO code 57 21 620

(13): PVC earth inspection pit 250mm diameter ELEMKO code 60 09 028 tested according IEC EN 62561 - 5

(3) St/tZn \varnothing 10 round conductor ELEMKO code 64 00 011 tested according IEC EN 62561 - 2

(2): Aluminium \varnothing 8 round conductor ELEMKO code 64 40 008 tested according IEC EN 62561 - 2

All dimensions in mm

		TITLE :	
		Construction of down conductor Res 7, Hung 5, Hung 4	
FIRST ISSUED	January 2020	DRG NO.	
DRAWN BY	Dionysopoulos G.	093-0	
CHECKED BY	Kokkinos D.	http://www.elemko.gr elemko@elemko.gr	
APPROVED BY	Kokkinos D.		
SCALE	None	SHEET 1 OF 1	
ISSUANCE DATE	January 2020	A3	