


A

A




Description

Solid tape conductor tested according to IEC 62561-2, made out of hot dip galvanized steel (St/tZn). It is used as air termination conductor, down conductor and earth conductor.

B

B

Typical application



Description	Raw material	WxT	Item code	For use	
				Buried	Above ground
Bare tapes	St/tZn	30x3	64 01 333	✓	✓
Bare tapes	St/tZn	30x3,5	64 01 133	✓	✓
Bare tapes	St/tZn	40x4	64 01 143	✓	✓

		Title:	
		Bare tapes	
FIRST ISSUED	June 2016	Model	
DRAWN BY	Dionysopoulos G.		
CHECKED BY	Kokkinos N.	64 01 xxx	
APPROVED BY	Kokkinos N.	www.elemko.gr	elemko@elemko.gr
SCALE	None		
ISSUANCE DATE	July 2021	SHEET 1 OF 1	

All dimensions in mm