




A/A	Description	Material	ELEMKO code	IEC EN
1	Round conductor $\varnothing 10$	St/tZn	64 00 011	62561 - 2
2	Test joint	ZG	62 55 130	62561 - 1
3	Tape conductor 30x3	Cu/eSn	64 22 330	62561 - 2
4	Disconnecting link	Cu/St/eZn	66 56 000	62561 - 1
5	Stranded copper conductor	Cu/eSn	64 22 108	62561 - 2
6	Isolating spark gap	Metal, ceramic, PVC	66 01 102	62561 - 3



Title:

Box with isolating spark gap

FIRST ISSUED April 2019

DRAWN BY Dionysopoulos G.

CHECKED BY Triantafillidis A.

APPROVED BY Kiosse T.

SCALE 1:3

ISSUANCE DATE April 2019

Model

083



www.elemko.gr



elemko@elemko.gr

SHEET 1 OF 1