

Detail D

Detail C

Detail B

Detail A

Detail B


Detail D

Detail E

Detail C

At picture you can see the installation of blind rivet nut:

- 1) Drilling the metal panel
- 2) Install the blind rivet nut
- 3) Decompression blind rivet nut with hand riveter (ELEMKO code:65 04 000)



Conductor fastener on eternite or corrugated metal roofs (1). It is equipped with a stainless base which enables the fastener on the roofs fixing screws and round conductor (8).

"T" connection clamp (4) with round conductor (8)

Conductor fastener (5) with sealing washer (6), and blind rivet nut (7)

Round conductor (8)

Air terminal rod mounted on an air terminal conductor (2) with parallel clamp (3) & round conductor (8)

ITEM	DESCRIPTION	DETAIL	FOR CONDUCTOR			STANDARD IEC EN
			Copper (Cu)	Steel - Aluminium (St/tZn - Al)	Stainless steel (SSt)	
1	Conductor fastener	A	61 22 102	61 02 102	61 22 102	62561 - 4
2	Air terminal rod	B	64 21 104	64 41 106	64 21 104	62561 - 1&2
3	Parallel clamp	B	62 28 308	62 08 308	62 28 308	62561 - 1
4	"T" connection clamp	C	62 21 810	62 01 810	62 61 810	62561 - 1
5	Conductor fastener	D	61 21 100	61 01 100	61 61 100	62561 - 4
6	Sealing washer	D	61 03 201	61 03 201	61 03 201	-
7	Blind rivet	D	65 04 409	65 04 409	65 04 409	-
8	Round conductor	A,B,C,D,E	64 20 008	64 00 108 - 64 40 008	64 60 008	62561 - 2



Title :  
Conductors fasteners on corrugated metal roofs

FIRST ISSUED	November 2016
DRAWN BY	Dionysopoulos G.
CHECKED BY	Kokkinos D.
APPROVED BY	Kokkinos D.
SCALE	None
ISSUANCE DATE	November 2016

DRG NO. 008  
<http://www.elemko.gr>  
 elemko@elemko.gr  
 SHEET 1 OF 1

All dimensions in mm