



Detail A

≤300

Detail D

Detail C

Detail B

3

6

Detail D

Conductor fastener (6) \varnothing 8-10mm with tightening torque 3,5 Nm and round conductor (3)

4

2

1

≤300

3

Detail A

Cross and "T" connector (1) \varnothing 8 - 10 / \varnothing 16mm with tightening torque 13 Nm, round conductor (3) air terminal earth lead - in rod fastener with tightening torque 3,5 Nm (4) and air terminal rod (2)

Note: Air termination rod base without the need for drilling the panel roof.

3

5

Detail B

Clamp fastener for earth termination system (5) with tightening torque 17 Nm and round conductor (3)

1

3

7

Welded

Sealant

1

3

Detail C

Cross and "T" connector (1) \varnothing 8 - 10 / \varnothing 16mm with tightening torque 13 Nm with roof bushing (7) and round conductor (3)

| Item | Description | Detail | For conductor | Standard |
|------|---|---------|----------------|-----------|
| | | | Aluminium (Al) | IEC EN |
| 1 | Cross and "T" connector | A,C | 62 48 115 | 62561 - 1 |
| 2 | Air terminal rod | A | 64 40 506 | 62561 - 2 |
| 3 | Round conductor | A,B,C,D | 64 40 008 | 62561 - 2 |
| 4 | Air terminal fastener \varnothing 16 mm | A | 61 41 300 | 62561 - 4 |
| 5 | Clamp fastener for earth termination system | B | 62 01 005 | 62561 - 1 |
| 6 | Conductor fastener \varnothing 8-10 mm | D | 61 41 100 | 62561 - 4 |
| 7 | Roof bushing | C | 64 41 200 | - |



Title :

| | | | |
|---------------|------------------|---------|-----|
| FIRST ISSUED | October 2017 | DRG NO. | 056 |
| DRAWN BY | Dionysopoulos G. | | |
| CHECKED BY | Papageorgiou T. | | |
| APPROVED BY | Kokkinos D. | | |
| SCALE | None | | |
| ISSUANCE DATE | October 2017 | | |

<http://www.elemko.gr> elemko@elemko.gr

SHEET 1 OF 1

All dimensions in mm