



(a) : The metal should be used as part of LPS certain requirements according to EN 62305-3.

ITEM	DESCRIPTION	DETAIL	FOR CONDUCTOR			STANDARD
			Copper (Cu)	Steel - Aluminium (St/tZn - Al)	Stainless steel (SSt)	IEC EN
1	"T" connection clamp	A	62 21 810	62 01 810	62 61 810	62561 - 1
2	Adjustable pipe clamp	B	65 62 205	65 62 205	65 62 205	62561 - 1
3	Air terminal rod with base	C	64 21 505	64 41 207	64 21 505	62561 - 1&2
4	Conductor fastener	D	61 21 100	61 01 100	61 61 100	62561 - 4
5	End clamp	E	62 25 442	62 45 441	62 45 441	62561 - 1
6	Round conductor	A,B,C,D,E,F	64 20 135	64 00 108 - 64 40 008	64 60 008	62561 - 2

		TITLE:	
		Air termination system (round conductor) - Bonding to metallic structures (handrails , lighting poles)	
FIRST ISSUED	December 2016	DRG NO. 015	
DRAWN BY	Dionysopoulos G.		
CHECKED BY	Kokkinos D.	www.elemko.gr elemko@elemko.gr	
APPROVED BY	Kokkinos D.		
SCALE	None	SHEET 1 OF 1	
ISSUANCE DATE	December 2016		

All dimensions in mm