



All dimensions in mm

**Detail E**  
 (4): Cu/eSn end clamp ELEMKO code 62 25 443 tested according IEC EN 62561 - 1

**Detail G**  
 Connection between fence and gate with (6) SSt/V2A clamp with stainless steel screws type ELEMKO code 62 61 834 tested according IEC EN 62561 - 1, type H, 100kA, B1+B4, B2, (7) Cable H07V-R 25mm<sup>2</sup> ELEMKO code 64 26 225 and (8) press terminal ELEMKO code 65 22 025

**Detail A**  
 (1&1.1): SSt/V2A clamp with stainless steel screws , ELEMKO code 62 61 836 tested according IEC EN 62561 - 1, type H, 100kA, B1+B4, B2

**Detail B**  
 (2): SSt/V2A clamp with stainless steel screws, ELEMKO code 62 61 834 tested according IEC EN 62561 - 1, type H 100kA, B1+B4, B2

**Detail C**  
 (5): Stranded copper conductor (Cu) 35mm<sup>2</sup>, ELEMKO code 64 20 135 tested according IEC EN 62561 - 2

**Detail D**  
 (7): Cable H07V-R 25mm<sup>2</sup> ELEMKO code 64 26 225

		<b>Title:</b>	
		Earthing of solar panel façade foundation pile, fence and gate	
FIRST ISSUED	July 2019	DRG NO.	086
DRAWN BY	Dionysopoulos G.		
CHECKED BY	Kokkinos N.	www.elemko.gr  elemko@elemko.gr	
APPROVED BY	Kokkinos N.		
SCALE	None	SHEET 1 OF 1 / 3rd edition: Copper 35mm <sup>2</sup>	
ISSUANCE DATE	November 2019		

1 2 3 4 5 6 7 8

A B C D E F

1 2 3 4 5 6 7 8 A3