

6000

Detail D

Detail C

Detail A

Detail C

Detail C

Detail D

Detail B

All dimension in mm

(2)

(3)

(1)

1000

1700

800


(4)

Detail B

For the placement an Earth electrode "E" ,™ind type ELEMKO 63 01 000 (4) it is necessary to open a tray with width 800 mm, length 1700 mm and depth 1000mm.


Detail A

St/tZn mast 4,4m height, ind.type ELEMKO 6006004 (1), 2m Franklin mast ind.type ELEMKO 64 21 103 (2) and Franklin connector ind.type ELEMKO 64 21 031 (3)



Detail C

SSt/V2A conductor fastener with inox contact ind.type ELEMKO 62 68 015 (5)



Detail D

Cu round conductor Ø8mm ind.type ELEMKO 64 20 008 (6)

		Title:	
		6m mast earthing to E™	
FIRST ISSUED	November 2020	DRG No.	096
DRAWN BY	Dionysopoulos G.		
CHECKED BY	Klampana M.	http://www.elemko.gr elemko@elemko.gr	
APPROVED BY	Kokkinos D.		
SCALE	None	SHEET 1 OF 1	
ISSUANCE DATE	November 2020		

SHEET 1 OF 1

A3