

PRODUCT DATA SHEET

LIGHTNING PROTECTION AND EARTHING SYSTEM COMPONENTS

Code: 61 21 202 (copper fastener) / 61 21 203 (tin plated copper fastener) **Description: Tape fastener**

ed.02/2021

Page 1 of 2

Application

Fastening tape conductor. Used in air termination system, down conductor system. Suitable for brick or concrete surfaces.

Classification as per IEC EN 62561

- Metallic.
- With screws.
- Designed to clamp but allow axial movement of the conductor.



Technical characteristics

Material	Fastener: Copper (Cu) and/or tin plated copper (Cu/eSn) Spacer: Plastic (PL)
Screws	M6x16 mm, V2A stainless steel screws One stainless steel wood fixing screw
Withstands (according to IEC EN 62561-4)	Lateral load, 200 N Axial load, 50 N

Withstands (according to IEC EN 62561-4)	Lateral load, 200 N Axial load, 50 N
Installation instructions	
Conductor's dimensions	Up to 30x6 mm
Compatibility with conductors made of	Cu, Cu/eSn, SSt (Stainless Steel)
Tightening torque of conductor	3,5Nm
Fixing on brick or concrete	Through a wood fixing screw (included) and a PVC wall plug Ø8 mm (not included)
Spacing between fasteners of air termination conductors	≤500 mm¹).
Spacing between fasteners of down conductors	≤1000 mm for heights ≤20 m. ≤500 mm for heights ≥20 m.
Before and after of change of direction or clamp or	≤300 mm.

Testing as per IEC EN 62561

The component has successfully passed the testing requirements of standard IEC EN 62561-4 "Lightning protection system components (LPSC) - Part 4: Requirements for conductor fasteners". Test report No 31390 by accredited laboratory as per ISO 17025

Manufacturing Quality Control

Manufacturing quality control according standard ISO 9001

Country of Origin

Greece

Optional accessories²⁾

PVC sealing washer, ELEMKO code 61 73 202

contraction-expansion absorbing component.

Unit: piece / Package: 50 pieces

See below typical application of the fastener

We reserve the right to introduce changes in the component due to technical evolution.









¹⁾Where additional mechanical strength is required, e.g snow, strong winds etc, the spacing between the fasteners should be ≤300 mm.

²⁾ See relevant data sheet



PRODUCT DATA SHEET

LIGHTNING PROTECTION AND EARTHING SYSTEM COMPONENTS

Code: 61 21 202 (copper fastener) / 61 21 203 (tin plated copper fastener)

ed.02/2021 Page 2 of 2





