

### **PRODUCT DATA SHEET**

#### LIGHTNING PROTECTION AND EARTHING SYSTEM COMPONENTS

Code: 61 21 240 (copper fastener) / 61 21 241 (tin plated copper fastener) **Description: Tape fastener** 

ed.02/2021

Page 1 of 2

#### **Application**

Fastening tape conductor. Used in air termination system, down conductor system. Suitable for brick or concrete surfaces.

#### Classification as per IEC EN 62561

- Metallic.
- With screws.
- Designed to clamp but allow axial movement of the conductor.



#### **Technical characteristics**

Material	Copper (Cu) and/or tin plated copper (Cu/eSn)
Screws	M6x16 mm, V2A stainless steel screws One stainless steel wood fixing screw
Withstands (according to IEC EN 62561-4)	Lateral load, 200 N Axial load, 50 N

Installation instructions	
Conductor's dimensions	Up to 40x6 mm
Compatibility with conductors made of	Cu, Cu/eSn, SSt (Stainless Steel)
Tightening torque of conductor	3,5Nm
Fixing on brick or concrete	Through a wood fixing screw (included) and a PVC wall plug Ø8 mm (not included)
Spacing between fasteners of air termination conductors	≤500 mm <sup>1)</sup> .

Spacing between fasteners of down conductors ≤1000 mm for heights ≤20 m. ≤500 mm for heights ≥20 m.

Before and after of change of direction or clamp or contraction-expansion absorbing component.

≤300 mm.

#### Testing as per IEC EN 62561

The component has successfully passed the testing requirements of standard IEC EN 62561-4 "Lightning protection system components (LPSC) - Part 4: Requirements for conductor fasteners".

Test report No 31140 by accredited laboratory as per ISO 17025

# **Manufacturing Quality Control**

Manufacturing quality control according standard ISO 9001

# **Country of Origin**

Greece

# Optional accessories<sup>2)</sup>

PVC sealing washer, ELEMKO code 61 03 201

# Unit: piece / Package: 50 pieces

See following typical application of the fastener

We reserve the right to introduce changes in the component due to technical evolution.









<sup>&</sup>lt;sup>1)</sup>Where additional mechanical strength is required, e.g snow, strong winds etc, the spacing between the fasteners should be ≤300 mm.

<sup>2)</sup> See relevant data sheet



# **PRODUCT DATA SHEET** LIGHTNING PROTECTION AND EARTHING SYSTEM COMPONENTS

Code: 61 21 240 (copper fastener) / 61 21 241 (tin plated copper fastener) **Description: Tape fastener** 

ed.02/2021 Page 2 of 2



